

Portable Appliance Test (PAT) Completion Certificate

DETAILS OF THE CLIENT

Paul Collyer Big Little Theatre
Ivy House Farm Marsh Hollow
Hollington

Postcode: DE6 3GB

ADDRESS OF TESTING

Ivy House Farm Marsh Hollow
Hollington

Postcode: DE6 3GB



ENGINEER, NAME & SIGNATURE

Signature

P. Baker

Name

Paul Baker

Date

12/12/2024

*ANY LIMITATIONS AGREED ON TESTING *If any, reasons and with whom agreed

TESTING CARRIED OUT BY

Baker Electrical Services

The Swallows
The Swallows, Calwich, Ashbourne,
Derbyshire

DE6 2HE

Email bakerelectricalservices@btinternet.com

Web

Telephone 07545 846493

Registration No: EPP61272
(if applicable)

PAT TESTER SERIAL NUMBER

Seaward Prime test 100

DECLARATION

This is to certify the electrical appliances details in this certificate and record sheets have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical equipment. It does not guarantee the correct operation of the appliance for any length of time. Users of the appliance should be aware of any fault or defect that may occur with future use. Any doubt regarding the safety or correct operation of the appliance, the device should be removed from service for further inspection by a competent person.

ANY FAILED APPLIANCES SHOULD BE REMOVED FROM SERVICE UNTIL THE DEFECT HAS BEEN RECTIFIED



Appliances Passed

52

Appliances Failed

0

52

Total Appliances

PORTABLE APPLIANCE REGISTER

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
1	Air Blower 1	1	N/A	Garage	1	0.17	19.99	N/A	0.17	✓	13		12	Pass	
2	Air Blower 2	1	N/A	Garage	2	0.15	19.99	N/A	0.18	✓	13		12	Pass	
3	Air Blower 3	1	N/A	Garage	3	0.15	19.99	N/A	0.16	✓	13		12	Pass	
4	Air Blower 4	1	N/A	Garage	4	0.15	19.99	N/A	0.15	✓	13		12	Pass	
5	Air Blower 5	1	N/A	Garage	5	0.03	19.99	N/A	0.20	✓	13		12	Pass	
6	Air Blower 6	1	N/A	Garage	6	0.14	19.99	N/A	0.18	✓	13		12	Pass	
7	Air Blower 7	1	N/A	Garage	7	0.17	19.99	N/A	0.14	✓	13		12	Pass	
8	Air Blower 8	1	N/A	Garage	8	0.18	19.99	N/A	0.19	✓	13		12	Pass	
9	Air Blower 9	1	N/A	Garage	9	0.14	19.99	N/A	0.15	✓	13		12	Pass	
10	Air Blower 10	1	N/A	Garage	10	0.15	19.99	N/A	0.17	✓	13		12	Pass	
11	Air Blower 11	1	N/A	Garage	11	0.10	19.99	N/A	0.16	✓	13		12	Pass	
12	Air Blower 12	1	N/A	Garage	12	0.15	19.99	N/A	0.20	✓	13		12	Pass	
13	Air Blower 13	1	N/A	Garage	13	0.14	19.99	N/A	0.19	✓	13		12	Pass	
14	Disco Light 1	2	N/A	Garage	14	N/A	19.99	N/A	0.10	✓	5		12	Pass	
15	Disco Light 2	2	N/A	Garage	15	N/A	19.99	N/A	0.10	✓	5		12	Pass	
16	Snow Machine FX LAB	1	N/A	Garage	16	3.58	19.99	N/A	0.10	✓	5		12	Pass	

Repair Codes:

A = Replace plug
B = Rewire plug
C = Fit BS1361 sleeved plug
D = Fit rubber plug
E = Fit inline switch
F = Replace IEC lead
G = Replace lead
H = Other

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
17	Snow Machine FX LAB	2	N/A	Garage	16	8.58	19.99	N/A	0.10	✓	5		12	Pass	
18	Disco Light 3	2	N/A	Garage	18	N/A	19.99	N/A	0.10	✓	5		12	Pass	
19	Extension Coil 20 Mtrs	IEC	N/A	Garage	19	0.04	19.99	N/A	N/A	✓	13		12	Pass	
20	Extension Coil 30 Mtrs No1	IEC	N/A	Garage	20	0.09	19.99	N/A	N/A	✓	13		12	Pass	
21	Extension Coil 30 Mtrs No2	IEC	N/A	Garage	21	0.04	19.99	N/A	N/A	✓	13		12	Pass	
22	Extension Coil 30 Mtrs No3	IEC	N/A	Garage	22	0.06	19.99	N/A	N/A	✓	13		12	Pass	
23	Extension Coil 50 Mtrs	IEC	N/A	Garage	23	0.08	19.99	N/A	N/A	✓	13		12	Pass	
24	2-Way Extension Lead	IEC	N/A	Garage	24	0.08	19.99	N/A	0.10	✓	13		12	Pass	
25	4-Way Extension Lead	IEC	N/A	Garage	25	0.08	19.99	N/A	0.10	✓	13		12	Pass	
26	4-Way Extension Lead	IEC	N/A	Garage	26	0.08	19.99	N/A	0.10	✓	13		12	Pass	
27	4-Way Extension Lead	IEC	N/A	Garage	27	0.08	19.99	N/A	0.10	✓	13		12	Pass	
28	4-Way Extension Lead	IEC	N/A	Garage	28	0.08	19.99	N/A	0.10	✓	13		12	Pass	
29	4-Way Extension Lead	IEC	N/A	Garage	29	0.08	19.99	N/A	0.10	✓	13		12	Pass	
30	4-Way Extension Lead	IEC	N/A	Garage	30	0.08	19.99	N/A	0.10	✓	13		12	Pass	
31	6-Way Extension Lead	IEC	N/A	Garage	31	0.08	19.99	N/A	0.10	✓	13		12	Pass	
32	EIC Lead 1	1	N/A	Garage	32	0.05	19.99	N/A	0.10	✓	5		12	Pass	

Repair Codes:

A = Replace plug

B = Rewire plug

C = Fit BS1361 sleeved plug

E = Fit inline switch

F = Replace IEC lead

G = Replace lead

H = Other

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
33	EIC Lead 2	IEC	N/A	Garage	33	0.05	19.99	N/A	0.10	✓	5		12	Pass	
34	EIC Lead 3	IEC	N/A	Garage	34	0.05	19.99	N/A	0.10	✓	5		12	Pass	
35	EIC Lead 4	IEC	N/A	Garage	35	0.05	19.99	N/A	0.10	✓	5		12	Pass	
36	EIC Lead 5	IEC	N/A	Garage	36	0.05	19.99	N/A	0.10	✓	5		12	Pass	
37	EIC Lead 6	IEC	N/A	Garage	37	0.05	19.99	N/A	0.10	✓	5		12	Pass	
38	EIC Lead 7	IEC	N/A	Garage	38	0.05	19.99	N/A	0.10	✓	5		12	Pass	
39	EIC Lead 8	IEC	N/A	Garage	39	0.05	19.99	N/A	0.10	✓	5		12	Pass	
40	EIC Lead 9	2	N/A	Garage	40	0.05	19.99	N/A	0.10	✓	5		12	Pass	
41	EIC Lead 10	2	N/A	Garage	41	0.05	19.99	N/A	0.10	✓	5		12	Pass	
42	EIC Lead 11	2	N/A	Garage	42	0.05	19.99	N/A	0.10	✓	5		12	Pass	
43	EIC Lead 12	2	N/A	Garage	43	0.05	19.99	N/A	0.10	✓	5		12	Pass	
44	EIC Lead 13	2	N/A	Garage	44	0.05	19.99	N/A	0.10	✓	5		12	Pass	
45	EIC Lead 14	2	N/A	Garage	45	0.05	19.99	N/A	0.10	✓	5		12	Pass	
46	EIC Lead 15	2	N/A	Garage	46	0.05	19.99	N/A	0.10	✓	5		12	Pass	
47	EIC Lead 16	2	N/A	Garage	47	0.05	19.99	N/A	0.10	✓	5		12	Pass	
48	EIC Lead 17	2	N/A	Garage	48	0.05	19.99	N/A	0.10	✓	5		12	Pass	

Repair Codes:

A = Replace plug

B = Rewire plug

C = Fit BS1361 sleeved plug

E = Fit inline switch

F = Replace IEC lead

G = Replace lead

H = Other

Appliance number	Appliance	Class	Polarity	Location	Serial number/ID	Test Results				Visual check	Fuse rating (A)	Formal Visual Inspection (months)	Combined Inspection & Test (months)	Result	Repair Code
						Earth continuity test(Ω)	Insulation Resistance M(Ω)	Load test (kVA)	Earth Leakage Test (mA)						
49	EIC Lead 18	2	N/A	Garage	49	0.05	19.99	N/A	0.10	✓	5		12	Pass	
50	EIC Lead 19	2	N/A	Garage	50	0.05	19.99	N/A	0.10	✓	5		12	Pass	
51	EIC Lead 20	2	N/A	Garage	51	0.05	19.99	N/A	0.10	✓	5		12	Pass	
52	EIC Lead 21	2	N/A	Garage	52	0.05	19.99	N/A	0.10	✓	5		12	Pass	

PAT Test Completion Certificate

Presented To

Paul Collyer Big Little Theatre

This is to certify the electrical appliances on the premises for the above named have been tested for electrical safety in accordance with the IET code of practice for in service and inspection and testing of electrical test equipment

Date 12/12/2024

PAUL BAKER

Tested by



Engineers Signature